

# **Safely Securing and Restoring Your Pump Station With Storms Eminent**

## **Securing Electrically**

Step 1: Turn the System Control Switch\* to the "OFF" position.

Step 2: Turn the Main Disconnect Switch to the "OFF" position.

## **Restoring Electrically**

Step 1: Take some time to conduct a visual inspection of power lines associated with your pump station and building. If any of the conductors or components appear burnt or damaged. Call the power company or your pump station service provider.

Step 2: Turn the Main Disconnect Switch to the "ON" position.

## **WAIT !!!**

Step 3: Wait 24 Hours in order to give the internal motor heaters time to remove condensation from the Motors! If at all possible wait an extra day.

Step 4: Turn the System Control Switch\* to the "ON" position.

Step 5: Charge the field as you typically would.

\*Although not all pump station manufactures refer to system start switch as the System Control Switch, we are referring to the switch on your particular panel which initiates the start sequence.

