



PCPI-2008-01 05/20/2008

NFRC PCP Interpretation – 2008

<i>Interpretation Requested:</i>
Can NFRC’s permanent labeling requirements be met by placing the required information on a permanent label beneath a stop or glazing bead?

<i>Date Requested</i>	<i>Initial Interpretation Date</i>	<i>Final CPC Approval Date</i>
03/19/2008	04/17/2008	05/20/2008

<i>Pertinent Document:</i>	
PCP-2008	
<i>Referenced Sections:</i>	<i>Referenced Pages:</i>
6.7	

<i>Interpretation:</i>
Yes, the location of this permanent label shall be in a consistent location as identified by the manufacturer in the NFRC CPD.

<i>Certification Policy Committee Revisions to Initial Interpretation:</i>