



PCPI-2008-05 12/03/2008

NFRC PCP Interpretation – 2008

Interpretation Requested:				
In order to comply with Canadian labeling requirements, can a door manufacturer list all required values (U-Factor, sizes, etc.) in “SI” followed by “(IP)” on the temporary Figure B-3 door label?				
PRODUCT DESCRIPTION:	U-Factor: W/m ² -K (Btu/h-ft ² -F)/Solar Heat Gain Coefficient			
	1/4 Lite ≤ 0.265 m ² (410 in ²)	1/2 Lite ≤ 0.581 m ² (900 in ²)	3/4 Lite ≤ 0.710 m ² (1100 in ²)	Full Lite > 0.710 m ² (1100 in ²)
2/ - /air/0.75	1.3 (0.23) / 0.12	1.7 (0.30) / 0.24	N / A	N / A

Date Requested	Initial Interpretation Date	Final CPC Approval Date
10/13/2008	10/16/2008	12/03/2008

Pertinent Document:	
PCP-2008-E0A2	
Referenced Sections:	Referenced Pages:
Appendix B	62

Interpretation:
Yes. The conversion factor used is 5.678263 When converting from IP to SI, the number of decimals used in the IP U-Factor shall be 2 with the SI U-Factor being reported to 1 decimal.

Certification Policy Committee Revisions to Initial Interpretation: