

SFPE Engineering Standard on Calculating Fire Exposures to Structures

SFPE S.01 2012

Errata

Revise paragraph 4.3.1.5 to read as follows:

Rectangular parallelepipiped spaces that (a) are not large; (b) have one or more vertical openings, e.g., openings through walls; (c) have known thermal conductivity and thickness of the compartment lining materials; (d) have a width-to-depth ratio of between 0.5 and 2.0; and (e) have no mechanical ventilation or flow-through wind shall be evaluated in accordance with the method in ~~4.3.2.3~~ 4.3.2.2.

Revise paragraph 5.3.2 to read as follows:

The temperature of the enclosure shall be calculated in accordance with the following equations ~~5.4.2.1 and 5.4.2.2~~.